

# CERTIFICATE OF COMPLIANCE

October 2015

## Invisi-Gard Fire Attenuation Certificate

Invisi-Gard has been tested in accordance with AS 1530.4 and achieves a fire attenuation rating of 43% at 40 kw/m<sup>2</sup> incident energy. Report Number: 2284200B.

The radiometer specification is in accordance with BS EN 1363-2:1999 18 April 2005.



Aluminium Specialties Group Pty Ltd

3 Alspec Place, Eastern Creek NSW 2766  
PO Box 262, Horsley Park NSW 2175  
Phone: 02 9834 9500 | Sales: 1300 ALSPEC  
Fax: 02 9834 9532  
[www.alspec.com.au](http://www.alspec.com.au)  
ABN: 63 001 252 259

**alspec**  
ALUMINIUM SYSTEMS  
SPECIALISTS